

## INTRA DEPARTMENTAL REVIEW MEMO

0036581

Messrs. Kirk, Shelton

Louis A. Cavanna

February 13, 1969

WORLD TRADE CENTER - CONTRACT WTC-113.00 - SPRAY ON FIRE  
PROOFING NORTH AND SOUTH TOWERS

ADDITIONAL INFORMATION: (INCLUDE PROJECT COORDINATOR, RESPONSIBLE DEPARTMENT)

- ☐ STAGE 1 DRAWINGS
- ☐ STAGE 11 DRAWINGS
- ☐ CONTRACT DRAWINGS
- ☒ SPECIFICATIONS
- ☐ ALTERATION APPLICATION
- ☐ PAI
- ☐ O&M STANDARD
- ☐ OTHER

FV

PLEASE REVIEW THE ABOVE MATERIAL AND RETURN COMMENTS BY

AM


ON 2 / 18 / 69 TO 1201

PM

COMMENTS:

Specifications - General

1. It is required that the spray fiber material be listed by U.L.
2. It is required that the sprayed-on-fire-proofing should conform to the latest changes of the New York City Administrative Building Code as indicated in the November 15, 1968 rulings of the Board of Standards and Appeals (copy attached).



Joseph S. Rand  
Engineer  
Inspection and Safety Division

JSR:gh



DIVISION HEAD

DATE